



WEEK OF: Monday, 3/16/2026

C-40355 NEW JAMAICA BUS DEPOT & PARKING LOT

Item	Threshold	Readings Below Threshold
Asbestos (during building remediation)	0.01 fibers/cc	N/A
Silica (during demolition)	25 ug/m3 8hr TWA	N/A
Particulate Monitoring (PM-10)	150 mcg/m3	Y
Volitile Organic Compounds (VOCs)	Background +5ppm	Y
Noise	Background +5dBA	Y
Vibration	1.0 in/sec	Y