



WEEK OF: Monday, 5/4/2026

C-40355 NEW JAMAICA BUS DEPOT & PARKING LOT

| Item | Threshold | Readings Below Threshold |
|---|------------------|--------------------------|
| Asbestos (during building remediation) | 0.01 fibers/cc | N/A |
| Silica (during demolition) | 25 ug/m3 8hr TWA | N/A |
| Particulate Monitoring (PM-10) | 150 mcg/m3 | Y |
| Volitile Organic Compounds (VOCs) | Background +5ppm | Y |
| Noise | Background +5dBA | Y |
| Vibration | 1.0 in/sec | Y |