

# SKANSKA

WEEK OF: Monday, 5/18/2026

C-40355 NEW JAMAICA BUS DEPOT & PARKING LOT

| Item                                      | Threshold        | Readings Below Threshold |
|---|------------------|--------------------------|
| Asbestos<br>(during building remediation) | 0.01 fibers/cc   | N/A                      |
| Silica (during demolition)                | 25 ug/m3 8hr TWA | N/A                      |
| Particulate Monitoring (PM-10)            | 150 mcg/m3       | Y                        |
| Volitile Organic Compounds (VOCs)         | Background +5ppm | Y                        |
| Noise                                     | Background +5dBA | Y                        |
| Vibration                                 | 1.0 in/sec       | Y                        |